

**DEPARTMENT OF PUBLIC HEALTH AND SOCIAL SERVICES
DIVISION OF ENVIRONMENTAL HEALTH**

2/A

PAGE 1 OF 1

SCHOOL BUILDING INSPECTION REPORT

REASON	INSPECTION DATE	ESTABLISHMENT NAME
Regular	08/07/2018	MERCY HEIGHTS NURSERY & KINDERGARTEN
Follow-up	INSPECTION TIME IN 10 HR. 00 MIN.	OWNER/OPERATOR SISTERS OF MERCY
Complaint	TRAVEL TIME AT 11 HR. 30 MIN.	LOCATION #211 SAN VITORES STREET, PEREZVILLE, TAMUNING
Investigation	SANITARY PERMIT # 180003119	PERMIT CATEGORY STATUS (Circle One) Permanent, Temporary/Current Expired
Other (Specify)		ESTAB. TYPE School

Based on an inspection this day the items listed below identify violations in operation or facilities which must be corrected by the next routine inspection or such shorter period of time as may be specified by the Department. Failure to comply may result in cessation of your operations.

ITEM NO.	REMARKS	CORRECT BY:	DATE
	A REGULAR INSPECTION WAS CONDUCTED TODAY. PREVIOUS INSPECTION DATED 04/12/2018 RESULTED IN A GRADE/RATING OF C/A. ALL PREVIOUS VIOLATIONS (ITEM # 19 & 37) WERE CORRECTED. THE FOLLOWING WERE OBSERVED TODAY:		
13.	WALLS AND CEILINGS THROUGHOUT BOY'S RESTROOM OF KINDERGARTEN AREA FOUND WITH DISCOLORATION DUE TO MOLD AND CONDENSATION; A SPOT ABOVE DOOR OF K-BLUE ROOM FOUND WITH DISCOLORATION DUE TO MOLD.		09/07/2018
	WALLS AND CEILINGS SHALL BE KEPT CLEAN AND IN GOOD REPAIR TO PREVENT GROWTH OF MOLD AND TO MAINTAIN THE SANITARY CONDITION OF THE FACILITY.		
	PHOTOS WERE TAKEN.		
	POSTED PLACARD "A" NO. 02697 ON WINDOW NEAR THE BUSINESS OFFICE AREA.		
	DISCUSSED THIS REPORT WITH MC. DEFANT, DIRECTOR.		

I have read and understand the above violation(s) and I am aware of the corrective measures to be taken.

*When any of the following items are cited above, they shall be corrected within ten days of the inspection: (01); (02); (23); (27); (31).

RECEIVED BY (Name and Title)

Belen Defant, Director

DEH INSPECTOR (Name and Title)

V. RAYMUNDO, BPHDI

300-9570